

## NOT TO SCALE

## NOTE

- 1. INLET MUST CONFORM TO ASTM C-478.
- 2. MAXIMUM DEPTH FROM INVERT OF OUTLET PIPE TO TOP OF FRAME SHALL NOT EXCEED 42 INCHES.
- 3. BENCHES MUST BE PROVIDED IN ALL INLETS.
- 4. ADJUSTMENT RINGS MAY BE EITHER CONCRETE OR HDPE WITH BUTYL RUBBER ROPE BETWEEN STRUCTURE-RING, RING-RING, AND RING TO FRAME.

REVISED 12-16-24



INLET DETAIL

