



NOTE

1. SUMP PUMPS SHALL BE DESIGNED WITH A MINIMUM 2" AIR GAP. A RIGID FOUR-INCH (4") DIAMETER PVC PIPE CAN BE USED TO CONNECT THE INDIVIDUAL SUMP PUMP SERVICE TO THE STORM SEWER. IN NO EVENT SHALL THE SUMP PUMP DISCHARGE INTO THE SANITARY SEWER SYSTEM.
2. NDS POP-UP EMITTER OR EQUAL.

REVISED 12-16-24



SUMP PUMP DISCHARGE CONNECTION DETAIL

